



FIRE FLOW COMPLIANCE/HYDRANT FLOW DATA

California Fire Code and District Fire Code require new construction and addition/remodels to meet fire flow standards.

Hydrant Flow Test

- A Hydrant Flow Test will be required when there is a: Demo/Rebuild, New Construction, and Additions (Attic/Basement/Detached Storage - Conditioned or Unconditioned).
- Site plan showing location of hydrant and shows distance of the hydrant to the furthest point of the house. (Through an approved route of travel)
- Who is the water purveyor?
 - If it is a private water company, schedule a hydrant flow test through NTFPD: [Schedule your flow test here](#). You will be required to notify the water purveyor of the flow test. Failure to do so will result in appointment cancellation and additional cost recovery fees.
 - If it is any of the PUDs (NT or TC), you will need to schedule the hydrant flow test with them, and you will need to reach out to that specific agency. NTF is not able to perform a flow test on a PUD hydrant. In some cases, the PUD may already have the flow test data available.

Chapter 5, Section 507 provides the requirements and provides information to request alternate means of protection.

Contact Information for the PUDs

Tahoe City Public Utility District
221 Fairway Dr, Tahoe City, CA 96145
(530) 583-3796

North Tahoe Public Utility District
875 National Ave, Tahoe Vista, CA 96148
(530) 546-4212